

Public Health Engineering Department District Water- Testing Laboratory Gwalior

Test Report


Type of sample: Water Sample		Particular of sample : collected / not collected by PHED	
Particular of sender:- : Principal Venus Public School, Sector-2 ,Anand Nagar Gwalior (M.P.)			
Sample No.	Place of Collection and Details of Sample		Date of collection
1	Drinking Water		05.10.2026
2	-		-
3	-		-
4	-		-
Particular of Sample :			
Date of Receipt: 05.10.2026		Time of Receipt: 02:15 PM	
Lab Reference No:		Date of Analysis: 06.10.2026	

Nature of Study – Chemical and Bacteriological Analysis

S.N.	Characteristics	Unit	As Per BIS-10500-2012 For Drinking Water		RESULT			
			Acceptable Value	Permissible limit in the absence of alternate source	Sample 1	Sample 2	Sample 3	Sample 4
PHYSICAL TEST								
1	Turbidity	NTU	1.0	5.0	1.4	-	-	-
2	Color	Cobalt	5	15	-	-	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionable	-	-	-
4	Temperature	C°	-	-	-	-	-	-
CHEMICAL TEST								
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	7.0	-	-	-
6	Alkalinity	Mg/L	200	600	124	-	-	-
7	Chlorides (as Cl)	Mg/L	250	1000	60	-	-	-
8	Nitrate as No3	Mg/L	45	45	6.2	-	-	-
9	Total hardness	Mg/L	200	600	194	-	-	-
10	Calcium as Ca	Mg/L	75	200	46	-	-	-
11	Magnesium as mg	Mg/L	30	100	18	-	-	-
12	Iron	Mg/L	0.3	1.0	0.10	-	-	-
13	Free Chlorine	Mg/L	0.2	1.0	0.0	-	-	-
14	T.D.S.	Mg/L	500	2000	520	-	-	-
15	Fluoride	Mg/L	1.0	1.5	0.11	-	-	-
16	Sulphate sa SO4	Mg/L	200	400	14	-	-	-
BECT. FEACAL TEST								
17	Total Coliform	per 100 ml	Nil		Nil	-	-	-
18	E Coli or Thermo tolerant coliforms	Per 100 ml	Nil		Nil	-	-	-

- This report should not be provided partially or fully without approval of signatory authorities for legal purposes.
- It is Recommended that acceptable limit is to be implemented values in excess those mentioned under " Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source, but up to the limits indicated under the "permissible limit in the absence of alternate Source"
- The results refer only to TEST samples and parameters TEST.
- Samples will be stored for a period of 10 days from the date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.


 Signature of Analyst
 District Water Testing Lab
 P.H.E. Division Gwalior


 Lab In charge
 District Water Testing Laboratory
 P.H.E.D. Division Gwalior (M.P.)
 P.H.E Division Gwalior (M.P.)

No. 467 /PHED/ Date :- 12/10/2026

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 467

Dated: 12/10/2026

It is certified that an inspection team headed by Mr. D.P. Singh Lab Incharge / Sub Engineer

(Name of Officers with designation) from Mrs. Anita Jayant chemist PHED Gwalior M.P.

inspected the Venus public school sector 2 Anand Nagar, Gwalior (M.P.)

(Name & Address of the school) on 7/10/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 467 dated 12/10/2026

of District water testing Laboratory (PHED Lab) Gwalior certified that

the Venus public school Anand Nagar (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One year [12/10/2026 to 11/10/2027]

Signature with Seal:

Name D.P. Singh

Designation Sub Engineer

Name & Address of the Office / Department: PHED Gwalior

Lab Incharge
District Water Testing Laboratory
P.H.E. Division, Gwalior (M.P.)

To

Principal
Venus public school Anand Nagar.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies